

FLUX+ WALL COMPACT

INSTALLATION & MAINTENANCE MANUAL




Table of Contents

GENERAL	4
1 • General	5
1.1 • Purpose of this manual.....	5
1.2 • Training	5
1.3 • Version control	6
1.4 • Language version.....	6
1.5 • Symbols used	6
1.6 • Abbreviations.....	7
1.7 • Definitions	8
INSTALLER	9
2 • Set up and installation (Safety)	10
2.1 • General instructions and safety instructions	10
2.2 • Safety regulations.....	11
2.3 • Device operation.....	12
2.4 • Specific measures	12
2.5 • Electrical	13
2.6 • Personal Protective Equipment (PPE).....	13
2.7 • Privacy Statement.....	14
3 • General description of the Renson Flux+ Wall Compact Unit	15
3.1 • Demand-driven ventilation and heat recovery	15
3.2 • Operating principle	15
3.3 • Fan control	16
3.4 • Bypass function	17
3.5 • Breeze function.....	17
3.6 • Fire Safety function	17
3.7 • Service properties	17
3.8 • Identification	18
3.8.1 • Identification label	18
3.8.2 • Information to be provided when contacting RENSON®	18
3.9 • Warranty terms and conditions.....	18
4 • Material, packaging and transport	19
4.1 • Transport	19
4.2 • Material, packaging and environment	19
4.3 • Disposing of the unit	19
5 • Ventilation unit description	20
5.1 • Components of the Flux+ Wall Compact unit.....	20
5.2 • Dimensions	21
5.3 • General installation conditions	22

6 • Installation.....	23
6.1 • Choice of installation	23
6.1.1 • Wall installation.....	23
6.2 • Preparing the unit for installation	24
6.2.1 • Parts	24
6.2.2 • Tools	24
6.3 • Marking the suspension bracket.....	24
6.4 • Condensation drainage point	26
6.5 • Installation dimensions	28
6.6 • Connections	28
6.7 • Wall installation	29
6.7.1 • Parts.....	29
6.7.2 • Mounting the unit.....	29
7 • Flux+ Wall Compact connection diagram	33
7.1 • Flux+ Wall Compact circuit board	33
7.2 • Linking via main circuit board in and outputs	34
7.2.1 • Digital inputs	34
7.2.2 • Analogue input	35
7.2.3 • Functional logic.....	35
7.2.4 • Digital output.....	36
7.3 • Connecting the Flux+ Wall Compact with electronic peripherals	36
7.3.1 • 3-Position Switch (XVK3).....	36
7.3.2 • Room sensors	37
7.3.3 • Electric frost protection	38
7.4 • Connecting to the mains voltage	39
8 • Starting up the Flux+ Wall Compact	40
8.1 • Before calibration	40
8.2 • Start up	40
8.2.1 • Calibration via the installation app.....	41
8.2.2 • Fault codes at start up.....	46
8.3 • Control panel.....	47
8.4 • Status LED module	48
8.5 • Connect to network.....	49
8.5.1 • Wi-Fi dongle	49
8.5.2 • LAN connection.....	50
8.6 • Connectivity Led strip	51
9 • Digital support from start to finish	52
9.1 • Installer web portal	52
9.2 • Installation report.....	53
10 • Maintenance	54
10.1 • Periodicities.....	54
10.2 • Cleaning and replacing filters	54
10.3 • Cleaning the heat exchanger.....	56
10.4 • Cleaning the ventilation unit	58
11 • Technical documentation.....	59
11.1 • Technical specifications.....	59

GENERAL

1 • General

The RENSON® Flux+ Wall Compact is a balanced ventilation system with heat recovery. The unit brings fresh air into the home mechanically and removes polluted air from the home mechanically using 2 integrated fans. The Flux+ Wall Compact is a professional product and must only be installed by a qualified installer. There are 3 manuals for the Flux+ Wall Compact: two for the installer and one for the user.

- The **installation manual** contains all the necessary information for installation, troubleshooting and maintenance.
- The **quick start guide** provides a clear step-by-step plan for the installer to assemble the unit.



- The **user manual** has all the necessary information for the use of the unit, simple maintenance and troubleshooting.



1.1 • Purpose of this manual

This manual contains instructions and recommendations for correctly sizing the Renson Flux+ Wall Compact Unit and then safely mounting, commissioning and maintaining it. Please read this manual carefully before connecting or maintaining the unit.

This manual starts with a general description of the Renson Flux+ Wall Compact Unit. Read these chapters first to familiarise yourself with the function and location of the most important parts. This is followed by Renson Flux+ Wall Compact Unit procedures:

- to install.
- to calibrate.
- to commission.
- to maintain.

1.2 • Training

- Only a certified installer may install, operate and maintain the unit unless otherwise stated. The proper functioning of the Renson Flux+ Wall Compact largely depends on correct installation and start up. Our experienced trainers are ready to provide you, the installer, with all the training and associated tips & tricks.

More info: <https://renson.net/gd-gb/pro/renson-academy>



1.3 • Version control

This manual is only available electronically as a PDF file.

RENSON® reserves the right to make technical changes to the products described. The most recent manual is available for download at www.renson.eu.



1.4 • Language version

This Dutch version is the original version. Any other language versions are translations. In case of incompatibility, the Dutch version is the standard version.

1.5 • Symbols used



Read the manual.



Tip: non-essential, useful information.



Warning: Failure to perform the procedure correctly may result in undesirable results or damage to the Renson Flux Wall Unit.



Danger: failure to perform the procedure correctly may result in personal injury.



The **CE mark** indicates that, according to the manufacturer, a product meets all EU requirements in terms of safety, health and environmental protection.



UKCA mark: the product complies with the regulations of the relevant laws in England, Wales and Scotland.



Warning for dangerous electrical voltage.
The product operates at high voltages.



Device to be used indoors.



This electrical appliance must be returned separately from residual waste by the owner.

1.6 • Abbreviations

The following abbreviations are used in this manual:

Abbreviation	Meaning
CERTIFICATION	
AREI	Belgian General Regulations for Electrical Installations
UKCA	UK Conformity Assessed
EAC	Eurasian Conformity Certificate
EMC	Electro-Magnetic Compatibility
AIRFLOW WTW SYSTEM	
EHA	Exhaust air, polluted extraction air that is blown outside
ETA	Extracted air, polluted extraction air from the home
ODA	Outdoor air, fresh air that enters the home
SUP	Supply air, fresh air that is blown into the home
HA 	House connection (ETA & SUP) – is indicated by a house
BA 	Outdoor connection (EHA & ODA) – is indicated by a tree
MATERIALS WTW SYSTEM	
EPP	Expanded and thermally insulating Polypropylene
SI UNITS AND GENERAL CONCEPTS	
Pa	Pascal, unit for pressure (1 Newton on 1 m ²)
ppm	Parts per million, a measure of concentration
CO ₂	Carbon dioxide, a measure of human presence
VOC	Volatile Organic Components, a measure of pollutants in the home
WTW	Heat recovery, a method for reusing heat

1.7 • Definitions

The following terms are used in this manual:

Term	Meaning
System D+	Ventilation system with mechanical supply and mechanical extraction of air
Unit	Renson Flux+ Wall Compact - 37314: Flux+ Wall Compact 275 - 37313: Flux+ Wall Compact 350 - 37309: Flux+ Wall Compact 275 ERV - 37311: Flux+ Wall Compact 350 ERV
Ventilation system	The unit with associated pipes and control elements
Pipe pressure	Every pipe system in a home has a characteristic pressure drop (pipe characteristic).
Plenum box	Distribution box to achieve both the supply and extraction air in the different rooms.
Valves	Adjustable openings that facilitate both supply air and extraction air in the different rooms.
Pulsion/Supply/SUP	Supplying air into the home
Extraction/ETA	Extracting air from the home
Bypass	A classic bypass provides an option to bypass the heat exchanger if no cold or heat exchange is necessary.
Thermal efficiency	The efficiency of the transfer of the heat or cold will result in thermal efficiency
Condensation drainage point	Depending on the temperature and humidity, the exchange of air flows and heat transfer results in the production of condensation, and the moisture must be removed via a condensation drainage point.
Filters	To protect the valuable unit (heat exchanger, fans, sensors), it is necessary to replace the 2 filters in the unit at regular intervals (see maintenance chapter).
Frost protection	If necessary, the unit will operate with imbalance at critical temperatures to prevent the heat exchanger from freezing.
Constant Flow	Regardless of the variation in air pressure due to indoor conditions or contamination of filters, the unit will always ensure the desired air flow rates are used. This also ensures the thermal efficiency is optimal at all times.
Wall installation	The device can be wall-mounted (see chapter 6. Installation for more details.) Thanks to the internal head box with top and side connections, the unit can be mounted to the ceiling. It can also be placed on the ground using the mounting base (37378).

INSTALLER

2 • Set up and installation (Safety)

2.1 • General instructions and safety instructions

The unit in this packaging complies with the prescribed CE safety regulations and UK Conformity Assessment.



Flux+ Wall Compact meets the legal requirements for electrical devices.

AREI

The socket used to connect the unit to the mains voltage must comply with the provisions of the AREI.

UKCA (UK Conformity Assessed)

The unit in the packaging complies with the prescribed UKCA safety regulations.

2.2 • Safety regulations

DANGER

- Ignoring the warnings below may result in malfunction or loss of performance as well as fire, electric shock or injury.
- A unit that has not been installed in accordance with the installation instructions is not covered by the warranty.

- This unit is intended for indoor domestic use. If you have a different situation, please contact RENSON®.
- Only an installer who has completed a Renson Flux training course may install, connect, commission and carry out maintenance on the Flux in deviation from the user manual.
- The Flux must NOT be placed in areas where the following are present or may occur:
 - Excessively greasy atmosphere
 - Corrosive or flammable gases, liquids or vapours
 - Ambient temperature above 40°C or below 0°C. To ensure proper operation, the Flux unit must be installed in a frost-free place. If this is not possible, the unit may, in exceptional cases, be installed in a location with an ambient temperature to -5°C, provided that the condensation drain is insulated.
- Relative humidity higher than 90% or outdoor installation (condensing environment)
- The unit and associated parts and controls must not be used in places where they may be subject to water jets.
- All wiring must be installed by a qualified person.
- When mounting, take into account the conformity of noise requirements according to the applicable standard (Belgium: NBN S01-400-1, Section 8).
- For the supply of fresh air and extraction of polluted air, the supply and extraction of the outside air must be provided via the roof (roof ducts) or via the wall (wall ducts). You must ensure the roof penetrations are sufficiently water-repellent and that the pressure drop is kept to a minimum.
- Only appropriate RENSON® accessories can be used with the unit.
- Changes to the Flux are not permitted.
- The unit cannot be opened without tools. Opening the unit may result in damage to the unit and/or personal injury.
- Observe national/regional/company regulations when working in confined spaces.
- The Renson Flux must be installed in accordance with the construction, safety and installation provisions generally and locally applicable in the municipality/city and/or all other bodies.
- If the power cable (37205) is damaged, it must be replaced by the manufacturer, its service representative or similarly qualified persons in order to avoid a hazard.
- The Renson Flux is constructed in such a way that it is impossible to come into contact with moving or live components during normal usage and without performing specific actions.
- The device must be installed so that it is touch-safe. This means, among other things, that under normal conditions no one can reach moving or live parts of the fan unit without taking a conscious action, such as:
 - Disassembling the cover plate.
 - Disconnecting an air duct and/or cover plate on the supply or discharge points during normal use.

WARNING

- The ventilation system must function permanently, which means the Flux must never be switched off (legal obligation according to NBN D50-001 Chapter 4.2 System D).
- The unit is only suitable for use in domestic homes. The unit is not suitable for industrial use, such as in swimming pools or saunas. Installation in an industrial environment may damage the unit.

2.3 • Device operation

- It is the installer's job to inform the user how the unit works and how it can be maintained (see user manual Chapter 'Maintenance').
- Only use the product for the applications for which it is designed as stated in the manual.
- Maintenance instructions must be followed precisely to prevent damage and/or wear.
- It is recommended to conclude a maintenance contract.

2.4 • Specific measures

! PLEASE NOTE

Ensure the Renson Flux+ Wall Compact remains easily accessible at all times so maintenance and servicing can be carried out smoothly.

- The Renson Flux complies with the legal requirements imposed upon electrical equipment.
- The Flux must not be installed at a height exceeding 2000m.
- Only appropriate RENSON® accessories can be used with the unit.
- Use RENSON® Easyflex air ducts to guarantee air transport according to the best air tightness class D.
- Provide RENSON® Aeroo valves for both extraction and pulsion. This results in lower energy consumption and lower noise production from the fans.
- Provide RENSON® Aludec air flexibles.
- Provide RENSON® Aludec air flexibles if you require acoustic damping.
- Provide RENSON® Isodec air flexibles or Easyduct fixed ducts if you require thermal insulation.
- Provide RENSON® roof and/or wall duct to minimise pressure drop. This results in lower energy consumption and lower noise production from the fans.
- The installer must ensure that the air exhaust of the fan unit is placed at a sufficient distance from the exhaust and supply of the heating boiler and sanitary air vent in accordance with the applicable regional regulations.
- It must not be possible to touch the fan with your hand. Therefore, an air duct network must always be connected to the Renson Flux before commissioning. The minimum channel length is 0.5 m.
- When the Renson Flux is combined with compartmentalisation products to reduce the risk of fire spreading: Ensure the fire damper/butterfly valve/cuff/etc. has sufficient free air passage to limit pressure loss. The incorrect choice of type can lead to poor functioning of the Renson Flux.

Consult our website <https://www.renson.eu/en-gb/producten/> for more information.



2.5 • Electrical

DANGER

- Connect the unit to a 230 VAC 50/60 Hz power supply using the included power cable or directly to the fuse box (see chapter 'Connection Diagram' of the installation and maintenance manual). Any other power connection will cause damage to the unit.
- The unit must function continuously, i.e. based on the applicable legislation (NBN D50.001), and permanent ventilation must be provided. In order to ensure proper functioning of this sensor-controlled system, the unit must never be switched off.
- Always switch off the power supply to the unit before you start working on the ventilation system. Leaving the unit open while it is operating could result in personal injury. Make sure the unit cannot be switched on accidentally. The unit can be disconnected from the power supply network by removing the power cable from the wall socket or by switching off the fuse. If there is any doubt, check whether this has actually happened.
- If no permanent wiring is provided and the power cable is damaged, it can only be replaced with a Renson power cable (item code 37205). If this is not respected and different wiring is used, any warranty and/or liability for the poor functioning of the product will be void.

Electronic components

Static electricity can cause damage to electronics.

WARNING

When working with electronics, always take protective measures such as wearing a grounded wrist strap.

2.6 • Personal Protective Equipment (PPE)

- Wear a helmet and safety shoes when certain parts are lifted or hoisted during installation. It is important that you wear a helmet, even when the unit is placed on the ceiling.
- Always wear gloves when handling metal parts such as the mounting plate as they may have sharp edges.



2.7 • Privacy Statement

- When the unit is connected to the internet, the unit automatically sends various unit data to Renson.
- For more information about this data processing, see www.renson.eu/privacy or contact us at privacy@renson.be.
- If a customer's Renson Flux+ Wall Compact is connected to your account via the user app, you have access to the personal data of that customer and you are a data processor within the context of the GDPR. In this case, you must comply with the responsibilities of a data processor imposed by privacy legislation. We initially recommend that you unlink your customer's unit from your account (via user app or user web portal) before the customer starts using the home. If you do not do this, you are responsible for complying with the requirements of privacy legislation.



TIP

The air quality sensor data is used to display (history) graphs to the user. As an installer, you do not automatically have the right to access the sensor data of a Flux+ Wall Compact you installed, in accordance with the General Data Protection Regulation (GDPR).

Access to the data can be requested via the Renson Installer Portal on the 'installation details' page.

Please note: This is only possible if the unit is online and the end user has created a Renson account.

3 • General description of the Renson Flux+ Wall Compact Unit

3.1 • Demand-driven ventilation and heat recovery


The Renson Flux+ Wall Compact is a balanced ventilation system with integrated heat recovery with counterflow heat exchanger. The unit brings fresh air into the home mechanically and removes polluted air from the home mechanically using 2 integrated fans. To guarantee optimal efficiency, the system must run in balance as much as possible (supply = extraction). The Renson Flux+ Wall Compact is a professional product and must only be installed by a qualified installer.

Proper functioning of the Renson Flux+ Wall Compact can only be guaranteed if sufficient and correctly dimensioned passage openings are provided in the interior doors of the home. A door grille or a gap can be placed under the door with a minimum airflow of 25 m³/h at 2 Pa.


3.2 • Operating principle

The Renson Flux+ Wall Compact is equipped with 2 sensor circuit boards:

- four sensors (ODA: RH + TEMP + VOC + CO₂) which measure the air drawn in from outside.
- four sensors (ETA: RH + TEMP + VOC + CO₂) that measure the air drawn in from the interior.



Left-hand configuration



Pos.	Name	Function
A	ETA	Extraction of polluted air from the interior
B	ODA	Fresh air flow from outside
C	EHA	Contaminated extraction air blown outside
D	SUP	Provide fresh air in the home

Maintaining air quality

- Flux+ Wall Compact operates via intelligent demand-controlled ventilation. Thanks to three central sensors that measure conditions 24/7, both noise levels and energy consumption are kept as low as possible.
- CO₂**: by default, ventilation continues above the basic level until the CO₂ level has fallen below 800 ppm. By comparison, outdoor air CO₂ levels are between 350 and 450 ppm.
- Humidity**: excessive humidity can lead to moisture build-up or mould growth and health issues such as eye, nose and respiratory problems. The ventilation system aims to maintain acceptable humidity levels.
- VOC (Odours)**: the ventilation system uses the central VOC sensor to ensure pollutants (such as those emitted by furniture) are also removed.

3.3 • Fan control

Constant flow technology

Using constant flow technology, the Flux+ Wall Compact ensures that the selected flow rate is continuously monitored, even as the filters become contaminated over time. Or when the pressures in the homes change due to doors being opened or closed, for example.

3.4 • Bypass function

A bypass ensures that during hot summer periods, relatively cool outside air (often at night) is routed directly indoors, without using the heat exchanger. The Flux+ Wall Compact has 2 valves for this purpose, allowing the device to separate air flows.

3.5 • Breeze function

By default, the Flux+ Wall Compact comes equipped with a Breeze function. The Breeze function supports natural cooling of the home during summer.

What does the breeze function entail?

When outdoor temperatures are soaring in the summer, the Flux+ Wall Compact helps by introducing fresh air during the night.; all connected rooms are ventilated at a higher flow rate (nominal flow rate).

Activating the Breeze function

Breeze control occurs automatically if the indoor temperature (measured by the internal sensors) is greater than the minimum temperature (e.g. 24°C) and greater than the outdoor temperature (also measured by the internal sensors). The minimum temperature can be set as desired in the app. When the Breeze function is active, it lasts for a minimum of 1 hour.


3.6 • Fire Safety function

Flux is equipped with an internal fire safety system. This means that when a certain temperature is reached, Flux will shut itself down. In this way, the unit switches off as soon as a critical temperature is detected, preventing a fire from being further fueled by fresh air supply. Flux also protects itself by not blowing excessively hot air through the device.


3.7 • Service properties

Start up via installer app:

The app guides the installer through the start up for a rapid, high-quality & reliable installation.



RENSON INSTALLER APP FOR
EASY CALIBRATION DURING
INSTALLATION



RENSON INSTALLER PORTAL FOR INSTALLATION PREPARATION +
POST-INSTALLATION VENTILATION REPORT

<https://installer.renson.eu>

Renson Installer Portal web portal - DIGITAL PASSPORT


The Renson Installer Portal web portal guides the installer from start to delivery. Some features:

- Project creation & pre-configuration
- Sending measurements report digitally
- Monitoring of connected devices

This ensures digitalisation and administrative **simplifying of the paperwork**

3.8 • Identification

3.8.1 • Identification label



Pos.	Info	Pos.	Info
A	Model / Type	D	Max. amperage
B	Mains voltage	E	Maximum power consumption
C	Warranty number		

! NOTE

- Never remove the identification plate of the unit.
- Make sure the identification plate is always accessible.

3.8.2 • Information to be provided when contacting RENSON®

Always provide the warranty number when you contact RENSON®, or when requesting service for your unit. The warranty number can be found on the identification label (section 3.8.1).


3.9 • Warranty terms and conditions

- The warranty period for the customer is 2 years.
- All pipes must be supported and mounted according to best practise. If any actions other than those mentioned are carried out, RENSON® is not responsible and the warranty will be void.
- Only an installer who has completed a Renzon Flux training course may install, connect, commission and carry out maintenance on the Flux+ Wall Compact in deviation from the user manual.
- Only appropriate RENSON® accessories and controls can be used with the unit.
- See chapter 2, safety and assembly instructions.

4 • Material, packaging and transport

4.1 • Transport

Please observe the necessary caution when transporting and unpacking the device. When stacking the units on a pallet for transport, 6 units may be placed at maximum, arranged in 3 layers of 2 units each. 1 unit weighs 21 kg. Avoid severe shocks during transport and handling. When transporting with a forklift, the units must remain attached to the pallet. The units are attached to the pallet by means of 2 straps. The packaging has been adjusted so that the unit can be transported without damage under normal circumstances. Preferably transport and store the unit with the pallet.



4.2 • Material, packaging and environment

After unpacking the device, make sure that the packaging material is disposed of in an environmentally-friendly manner. By recycling the packaging, raw materials are conserved and the amount of waste is reduced. The packaging consists entirely of EB corrugated cardboard and paper. No UPVC or plastic foams are used to package and protect the unit.



4.3 • Disposing of the unit

Old electrical and electronic devices often contain valuable materials. However, they also contain harmful substances that are necessary for the functioning and safety of the unit. Never dispose of the discarded unit with regular waste.




Dispose of the unit in an environmentally-friendly manner by taking it to the appropriate collection point.

5 • Ventilation unit description

5.1 • Components of the Flux+ Wall Compact unit

Exploded view of the Flux+ Wall Compact Unit:







A	Filter covers	J	Fan
B	Front plate	K	Filter
C	Condensation plate	L	Flanges
D	CO ₂ , humidity & VOC sensor	M	EPP cover
E	Sensor frame	N	Caps
F	Heat exchanger	O	Wall bracket
G	Foam	P	PCB with cover
H	Bypass valve	Q	Wi-Fi dongle
I	Pressure sensor		

A list of the parts available can be found at:



5.2 • Dimensions



5.3 • General installation conditions

Read the safety and installation conditions carefully.

- Choose the installation space in the technical room or elsewhere (near the roof or wall penetrations). Position the unit centrally in relation to the rooms to be ventilated so the duct lengths are distributed as homogeneously as possible and resistance across the duct network is limited. To limit possible noise transmission, do not place the unit above or in a bedroom.
- Make sure there is sufficient space around the unit to connect the ventilation ducts without problems and to carry out inspection and maintenance. Avoid obstacles that prevent access or removal of the unit.
- The unit must be placed in a frost-free room.
- The condensation drainage point must be connected to the home drainage point network.
- The Flux+ Wall Compact must not be connected to an extractor hood or dryer.
- Air supply and exhaust for the unit must always be directed outside.
- The dimensions of the required supply ducts are highly dependent on the intended extraction air flow rate and the total lengths. Follow best practices and the guidelines included with the materials used
- Avoid sharp bends in the pipes just before the fan unit.
- Insulated pipes should be used to prevent condensation in the ducts:
 - for the connections of the supply and extraction pipes from outside to the ventilation unit
 - if pipes are placed outside the insulated volume of the home
- Minimum density for wall/ceiling of 100 kg/m², because of firmness for mounting & sufficient mass for further vibration damping.
- Don't place any objects on the unit as this can result in the load capacity of the mounting system to be exceeded.

! NOTE

Placement of the Flux+ Wall Compact and the associated air ducts must be arranged in such a way that the air ducts can be connected with a minimum number of bends. This limits the resistance across the air ducts and capacity and noise problems are avoided.

💡 TIP

Renson recommends always providing 1 m of acoustic damping material Acoudec in the pulse & extraction side. Together with respecting the correct ducting rules to obtain an acceptable pressure drop, this ensures quiet operation of the ventilation system. Always place the sound absorber as close to the fan unit as possible.

In addition to choosing high-quality components (Easyflex, Acoudec, Isodec, etc.), correct installation is also essential for a well-functioning ventilation system. Correctly dimensioning the piping system plays an important role in this regard. Correct sizing of the pipe system significantly reduces fan consumption and improves acoustic comfort. The mechanical supply lines in ventilation systems D to the living areas in particular deserve extra attention. After all, mechanical supply is sensitive to acoustic discomfort. The table below provides an overview of the maximum recommended air flow rates through the Renson pipe components. Please note that this table does not address pressure drops. To limit the pressure drop across the channels, the length and especially the number of bends per channel must also be limited. If in doubt, please get in touch with your point of contact.

https://www.renson.eu/Renson/media/Renson-documents/BENG/renson_leidingsysteem/Tabel1_Dimensioneringstabel_Renson_leidingsysteem_NL.pdf




6 • Installation

6.1 • Choice of installation

De Flux+ Wall Compact is a device that can be mounted to the wall or on the floor using the optional mounting base (item code: 37378). Moreover, Flux Wall Compact can easily be changed from a left-hand configuration to a right-hand configuration. Defining the configuration is one of the steps when setting up a device in the Renson Installer App.

6.1.1 • Wall installation

Condensation drainage point is provided on the side where EHA is connected. Choose condensation drainage point number 1 for the left version; choose condensation drainage point number 2 for the right version.




6.2 • Preparing the unit for installation

6.2.1 • Parts

What do you need?

! The necessary parts for this installation are included in the standard packaging of the unit.

Number	Description	Quantity	Illustration
①	Suspension bracket	1	

6.2.2 • Tools


- Drill
- Screwdriver machine with bits
- Pencil, marker for marking

6.3 • Marking the suspension bracket


When marking out the position for the Flux+ Wall Compact, a minimum distance of 350 mm between the wall and the unit must be maintained to allow sufficient space for connecting the ducts.

After a choice has been made about the location of the ventilation unit, the location of the suspension bracket can be determined with:

1. The template (which is cut from the box)





- The simplest way to mark the drill holes on the wall is to hold the wall bracket at the correct height against the wall, using a spirit level, and transfer the hole positions with a pencil.



6.4 • Condensation drainage point

The Renson Flux+ Wall Compact has 2 condensation drainage points. The unused drainage point is closed off using the pre-assembled plastic cap. Be careful not to damage the plastic cap when removing it in order to prevent creating a leak when putting it back.

Each condensation point consists of a 1.25 inch (32 mm) external thread. An extraction point with a siphon or odour seal must be mounted to it. In the image, you can see an adapter piece that is included with the dry siphon kit (item code: 17792). Optionally, you can order this kit at Renson.




TIP

For proper water drainage without odour nuisance, it is highly recommended to use the Renson dry siphon kit (item code: 17792) for the Flux+ Wall Compact. Follow the instructions on the supplied sheet carefully to ensure proper functioning of the unit.

To ensure proper water drainage, make sure that the unit is installed at least 65 mm above the ground (for an angled connection), or at least 250 mm above the ground for a straight connection, so that condensate drainage can always be carried out correctly. The water drainage point must slope at least 1 cm/m to ensure a good drainage point.

Wall installation



6.5 • Installation dimensions

Provide **at least 65 mm (for angled connection) or 250 mm (for straight connection)** at the bottom of the unit at the level of the condensate connection.

In addition, a minimum distance of 350 mm must be maintained between the unit and the wall and/or ceiling on each side where a duct connection is present. If this duct connection consists of a Renson Isodec, Acoudec or Easyduct in Ø 160 mm, respecting this minimum distance ensures a small pressure drop and easy installation and disassembly for any service to be carried out.

6.6 • Connections

The Flux+ Wall Compact has a total of four internal plenums, each with Ø 160 mm internal diameter and Ø 160 mm external diameter connections. The unit is supplied with 4x installation flanges and 4x EPP caps by default. The following items can be connected to the installation flanges: The connection must always be finished airtight, e.g. by using ALU tape.

ATTENTION

Incorrect connections can cause damage to the unit.

- It is mandatory to use the supplied Renson flanges.
- Flanges must be installed in the correct direction: with the short side inwards and the stop against the unit.

• Renson Isodec

Renson Isodec	10 m	5 m
Ø 160 mm	11683	9499

• Renson Acoudec

Renson Acoudec	1 m	0.5 m
Ø 160 mm	9497	11681

• Renson Easyduct

Renson Easyduct	Fixed 1 m	90° bend	Sleeve
Ø 160 mm	11021*	17113	12009

* sleeve included

6.7 • Wall installation

6.7.1 • Parts

What do you need?


Description	Quantity	Illustration
The drill template that is part of the box	1	

NOTE

Mounting material to hang the unit on the wall is not supplied because this depends on the type of wall. It must be provided by the installer.

6.7.2 • Mounting the unit


- See section 6.3 2 for correctly marking out the drill holes.




TIP

Secure the bracket to the wall using M4 screws or larger. The recesses in the brackets are provided up to M6. When using M4 screws, a flat washer must be used.


2. Fix the bracket to the wall with 4 screws in the holes provided.
Make sure the bracket is perfectly level on the wall.




3. Move the unit to the installation location.
Hold the power cord off the ground while moving the unit. If the cord is left hanging loose, it could easily cause you to slip, trip or fall.




4. Hang the unit with its bracket over the wall bracket that has already been installed.



5. Adjust the unit using a 6 mm Allen key so that it is level with respect to the wall. Use the adjustment bolt located at the front on the underside of the front panel.




6. Connect the dry siphon to the correct side of the unit:
- Standard configuration: Right
 - Non-standard configuration: Left



7. Install accessories (if applicable) (see Chapter 7.3).
- room sensors
 - External electrical frost protection (14524)
 - active humidification module (36231)
 - 2-zone kit (36526)


By installing accessories in a timely manner, they are directly recognised by the software of the unit and included in the digital commissioning process. Furthermore, any potential pressure losses are immediately incorporated into the unit's pressure measurements and calibration.

9. Use the supplied flanges to connect the channels. The unused connection points are closed with a sealing cap. For Flux Wall Compact, we recommend ducts of Ø 160 mm.




7 • Flux+ Wall Compact connection diagram

7.1 • Flux+ Wall Compact circuit board



- **Mains voltage:** connect to the wall socket or directly to the fuse box.
- **USB ports:** the USB port can be used to:
 - Allow Flux+ Wall Compact to use Wi-Fi to communicate with the home network and/or directly with the app installer. Use the supplied Renson USB Wi-Fi dongle to do this.
 - Allow Flux+ Wall Compact to communicate via RF with the Sense room sensor(s). Use the RF dongle to do this.
- **Network port:** The connection can be used to connect Flux+ Wall Compact to the home network via a network cable.
- **External output:** The Flux+ Wall Compact can control external devices (a detailed description can be found in Chapter 7.3).
- **External input:** The Flux+ Wall Compact can be controlled by external devices via the digital and/or analogue input(s) (a detailed description can be found in Chapter 7.3).
- **Accessory port:** This is where you connect the accessories of Flux+ Wall Compact.

7.2 • Linking via main circuit board in and outputs




INSTALLER

7.2.1 • Digital inputs

The digital inputs can be controlled in 2 different ways:

1. **Potential-free contact:** via a continuously closed contact


Principle sketch:



External switch


Flux+ Wall Compact main circuit board

2. **Voltage control:** via a continuous signal;
→ [0-1.5VDC] sends a logical LOW,
→ [5-10VDC] a logical HIGH



7.2.2 • Analogue input

No function is connected to the analogue input (0-10V).



7.2.3 • Functional logic

The functionality of the inputs is firmly defined:

7.2.3.1 • Digital input

Closed contact or logic HIGH on the input	Flux+ Wall Compact operating status
1 DIG	Minimum position ⁽¹⁾ - Demand control inactive
2 DIG	Boost position ⁽¹⁾ - Demand control inactive


(1) After a period of 12 hours, the demand control of the Flux+ Wall Compact is reactivated.

If there is no control at the input, the Flux+ Wall Compact works in demand control (automatic mode).

7.2.3.2 • Analogue input

No function currently assigned.

7.2.4 • Digital output




Functional logic:

- Contact DIG 1: display if there is an error/warning on the device (incl. notification filter)
- Contact DIG 2: device filter warning

7.3 • Connecting the Flux+ Wall Compact with electronic peripherals


The Flux+ Wall Compact can be connected to electronic accessories. The provided recess can be used to route the cables outside the Flux+ Wall Compact.

You must route the cables this way:



7.3.1 • 3-Position Switch (XVK3)

Potential-free wired 3-position switch for manual adjustment of the ventilation extraction rates.



! REMARK

This means contact 2 does not need to be connected; contact 3 is connected to '2 DIG'.

7.3.2 • Room sensors

Renson room sensors can be combined with the Flux+ Wall Compact to regulate the local air quality via ventilation airflow rate. These 230 V-powered sensors communicate with the ventilation unit via a robust wireless connection. The RF Dongle serves as a bridge between the ventilation unit and the room sensors.

Adding room sensors further improves air quality and lowers the E-level.

7.3.2.1 • Sense room sensors

Sense are pre-configured room sensors kits in which the connection between Sense and the RF Dongle has already been established.

More information on the Sense room sensors and their installation can be found via the following link:




7.3.2.2 • Room sensors and controls for Flux

The room sensors still need to be paired with the Flux device, but thanks to automatic pairing they are very quick and easy to install. The room sensors are available in various versions to suit every need.


Article code	Description	Control	Sensor	Power	Installation	Communication
38442	CO ₂ sensor with controls - recessed	✓	CO ₂	230 V	Recessed	Radio frequency (RF)
38443	CO ₂ sensor with controls - wall-mounted	✓	CO ₂	230 V	Wall-mounted	Radio frequency (RF)
38444*	Four-position switch	✓	-	Battery	Wall-mounted	Radio frequency (RF)
11667	RF dongle	-	-	USB	Wall-mounted	Radio frequency (RF)

* Batteries and double-sided tape included


38444 - Four-position switch




38442 - CO₂ sensor with controls - recessed



38443 - CO₂ sensor with controls - wall-mounted



11667 - RF dongle



More info regarding the Flux Room Sensor and its installation can be found via the following link:



7.3.3 • Electric frost protection

By default, the Flux+ Wall Compact is equipped with a frost protection mechanism to prevent ice formation in the heat exchanger. Ice formation reduces the efficiency of your ventilation system and can damage the heat exchanger.

Each Flux+ Wall Compact unit is equipped with basic frost protection through unbalance operation.

In cold climates, it is recommended to use hybrid frost protection using an electric heating element. An external 1.2 kW electric heating element can be connected to the Flux ventilation system. This external frost protection is modulated based on the central temperature sensors.


More information on the external electrical frost protection and its installation can be found via the following link:



7.4 • Connecting to the mains voltage

Flux+ Wall Compact can be connected in 2 ways:


1. By plugging the supplied power cable into the socket (the socket should be located in an easily accessible place). Provide a power socket within 1.5 m around the unit.



2. By connecting directly to the fuse box. The wires of the cable should be stripped 6 mm before they are connected to the connector.

! NOTE

If the Flux+ Wall Compact is connected directly to the fuse box, a circuit breaker must be installed in the board to allow the Flux+ Wall Compact to be disconnected from the power supply. This unit must be of the double-pole type, must be directly connected to the Flux+ Wall Compact, and must be able to withstand category III overvoltages.



! The installation and electrical connection of the various components may only be carried out by authorised personnel in accordance with the applicable safety measures.

8 • Starting up the Flux+ Wall Compact

In this chapter we take you, the installer, through the installation flow of the application. Before following this step-by-step plan, please download the application from the respective store.

Start up and calibration of the unit can only be carried out with the Renson Installer App. In this way, you as the installer are fully unburdened and guaranteed that the calibration has been carried out correctly. By using the app, the entire process will be faster, easier and more correct.



TIP

- No internet or (Wi-Fi) network is required to calibrate the unit. A dongle is sufficient for calibration.
- We recommend switching off 4G/5G for the best possible connection to the Flux unit.



8.1 • Before calibration

Extreme weather conditions, such as strong winds, may affect the operation of the system. Avoid carrying out the calibration of the Flux+ Wall Compact under these conditions.



Before starting the automatic calibration it is important to:

1. Close all the windows and doors
2. Preferably close interior doors
3. Stop all other installations that bring outside air in or send indoor air out.
4. Install the Flux accessories (if applicable).

8.2 • Start up

The unique calibration procedure, together with the constant flow feature, greatly reduces the time for setting the desired design air flow rates.

1. Power up the unit and ensure the Wi-Fi dongle is installed.
 - Start up check: the operating system of the unit has started up (this takes about a minute).
 - The configuration check then takes place: the fans first speed up briefly and then continue to run at the minimum speed. The bypass valves are also calibrated.
2. Feedback (LED) during the start up phase
 - A complete overview of how the unit's LEDs behave during start up can be found in Paragraph 8.6.


8.2.1 • Calibration via the installation app







The **Renson Installer app** can be downloaded for free from the App Store (Apple) or Google Play (Android). Register to create an account.

Your benefits from calibration with the Renson Installer app:

- Guide through the installation process
- Desired nominal air flow rates can be set/adjusted in a simple manner
- Configuration can be easily adjusted
- Overview of the pressure losses of the installation (after calibration)
- If a fault is detected during calibration, a message with a suggested solution appears
- The installation data is forwarded to the web portal
- An installation report is automatically created digitally in the web portal
- All started installations can be managed in the web portal

The installer is guided through the steps below during installation in the app:





Via Wi-Fi Dongle:
Connect your phone to the Flux device's Wi-Fi. It is recommended to switch off the mobile data.- on your phone.

Via Ethernet cable:
Connect your mobile phone to your home network. Select the Flux device in the Installer app. No authorisation is required.

Shortly (<5 sec) press the button to authenticate. The Flux unit will now connect with your app.

The installer app indicates when software updates are available. Non-critical updates can be skipped.

NOTE

If electric frost protection is installed as an accessory, you must update the software to version 2.7.3 or later. The software update is performed in two steps, for iOS and Android.

6

09:56

Connected

Flux+ Wall 475
Warranty n°: XUD487920014A32
Firmware version: 2.7.3
OS version: 2.7.3
WebApp version: 2.7.3

Choose the position of the device and select the country the device will be installed. Then tap 'Start' to configure.

Position
Left (factory default)

Types of room valves
One or more Aeroo valves

Country
Belgium

Back Start

7

09:56

Define extraction valves

Extraction rooms Flow rate

No.	Zone type	Qnom [m³/h]
1	Bathroom with toilet	50
2	Hallway	50
3	Open kitchen 1	75
4	Laundry room	50
5	Toilet 1	25
6	Toilet 2	25
7	Open kitchen 2	75

Add or change rooms

Back Next

09:56

Define extraction valves

Extraction rooms Flow rate

No.	Zone type	Qnom [m³/h]
1	Bathroom with toilet	50
2	Hallway	50
3	Open kitchen 1	75
4	Laundry room	50
5	Toilet 1	25
6	Toilet 2	25
7	Open kitchen 2	75

Add or change rooms

Back Next

Define all extraction valves. The flow rate per valve can be adjusted.

8

09:56

Define pulsion valves

Supply rooms Flow rate

No.	Zone type	Qnom [m³/h]
1	Bedroom 1	50
2	Bedroom 2	50
3	Hallway	50
4	Living room 1	50
5	Living room 2	50
6	Living room 3	50
7	Office	50

Add or change rooms

Back Next

09:56

Define pulsion valves


Supply rooms Flow rate

No.	Zone type	Qnom [m³/h]
1	Bedroom 1	50
2	Bedroom 2	50
3	Hallway	50
4	Living room 1	50
5	Living room 2	50
6	Living room 3	50
7	Office	50



Add or change rooms

Back Next




Define all supply valves. The flow rate per valve can be adjusted.





Overview page. Flow rates can't be adjusted anymore.





The flow rates can be measured in any order. In the next step, the valve positions must be adjusted in reverse order.



When using Aeroo valves, the installer app displays the recommended valve position.



The service page provides you information on the Flux ventilation unit and its accessories.



Select the home network to which the device should be connected, then enter the Wi-Fi password. The device will now connect automatically.

This step does not apply if the unit is connected via an Ethernet cable



TIP

After successful calibration, you also have the option to create an installation report (see 9.2), which can be used for SKH, etc.

8.2.2 • Fault codes at start up

Two types of faults are defined:

- **Error:** the unit is experiencing a serious malfunction and will shut itself down
- **Warning:** The unit is experiencing a fault, but can/will continue to operate

The faults can be observed in several ways:


- **Installation app**

- If a fault occurs **during the initialisation process**, a message will appear.

How to continue the installation process?

Error	Requires corrective action to continue the installation process.
Warning	Taking corrective action is advised. However, the installation process can continue without corrective action.

- The list of possible malfunctions (and associated solutions) can be found through the 'Support' menu in the Renson Installer App. The app must be connected to the internet (via Wi-Fi or mobile 4G/5G).



- **Status LED of the unit**


The LED bar always shows the status of the unit, see Section 8.4.

! REMARK

If the unit is without power for a short time, all error messages will be deleted.


8.3 • Control panel

If the unit is connected to the internet, the control panel allows you to communicate with the unit via the push buttons. We recommend this given the extensive functionality associated with it. The unit can be accessed perfectly via the app, which can be found in the Play store (Android) or via the App Store (iOS). In this chapter, we will discuss the physical control and the colour codes of the indicator LED.



Pos.	Name	Function
A	Status LED	Changes colour depending on the status of the unit (see below for more explanation about the different colour codes).
B	Connectivity LED	- Green continuous LED: the device is connected to a network, either via the Wi-Fi dongle or the Ethernet cable. - flashing blue LED: AP is active - Alternating green blue flashing LED: device is connected and AP is active - LED does not light up: AP is not active nor is the unit connected to Wi-Fi
C	Large user push button	- When pressed briefly, this button is used to complete authentication of the device. - After cleaning and replacing the filters, you must reset the filter message by pressing this button for 5 to 15 seconds - If this button is pressed for a long time (>15sec), the access point (AP) is activated for 4 hours. The AP can also be activated by reinserting the plug of the unit into the power socket
D	Reset button	- If this button is pressed briefly, the C-mode will be activated and the unit will operate at its nominal flow rate for 2 hours. - If this button is pressed for 5 to 15 seconds, the Wi-Fi settings are reset. The device will forget the connection to the home network as a result. - If this button is pressed for a long time (>15sec), the unit is returned to factory settings. Use a pen or another small object to push the button.
E	Accessory port	Connection point to connect Renson accessories. E.g. 2-zone kit. No Ethernet cables should be connected to the accessory port; it should be connected to the network port (H).
F	USB port 1	This is where the Wi-Fi dongle or RF dongle can be plugged in. It can be placed in any of the USB ports. The USB port can be used to: - Wi-Fi dongle: communication with the home network and/or directly with the installation app. - RF dongle: communication with the room sensor(s)
G	USB port 2	
H	Network port	To connect the unit to the LAN network via a cable. If a Wi-Fi dongle is used via USB port 1 or 2, it is not necessary to connect the unit with a fixed cable. Tip: the most stable solution is to connect the unit with a cable.

8.4 • Status LED module



WHITE



The status LED (A) is continuously lit white. The unit starts up. This is what you will see when the unit has just been plugged into the socket.

The LED will go out briefly afterwards. This is when the configuration is checked.

Please note: during the start up phase, a connection cannot be made with your unit via the application.

LIGHT BLUE



The status LED (A) flashes to indicate that you must complete the authentication. To do this, press the large user push button (C). The LED will now briefly light up continuously. This indicates the authentication was completed successfully.

GREEN



The status LED (A) flashes slowly to indicate that the unit was not yet calibrated with the application. This means the air flow rates have not yet been set for the various rooms in the home. When the unit is calibrating, you will see the status LED (A) flashing rapidly. Once the calibration has been completed successfully, you will see the LED light up continuously.

BLUE



The status LED (A) is flashing. This means C-mode has been activated (the mode where the unit provides nominal airflow for 2 hours) and your unit is now running at its set nominal mode. In this mode you can also measure the air flow rates at the various ventilation openings to check whether the airflow rates are as intended.

RED



The status LED (A) is slowly flashing red. This indicates that a critical problem has occurred with the unit. We recommend using the application to obtain more information about the error that has occurred (see Warning Paragraph 8.2.2).

CONTINUOUS YELLOW



The status LED (A) is continuously lit in yellow. This indicates that a problem has occurred with the unit. You can easily investigate what the problem is via the app on your smartphone (see Error Paragraph 8.2.2).


FLASHING YELLOW



The status LED (A) is rapidly flashing in yellow. This is an indication that the filters need to be cleaned. Cleaning/replacing filters is described in Paragraph 10.2. Next, press and hold the large user button (C) for 5 seconds to indicate that the filter has been properly cleaned; the filter alert will be reset automatically.

8.5 • Connect to network

8.5.1 • Wi-Fi dongle



Wi-Fi dongle is already factory-connected and installed with Flux+ Wall Compact.
The Wi-Fi dongle can then be used to connect the Renson Flux+ Wall Compact with:

1. Renson Installer App
The app guides how the installer can make the connection between the app and Renson Flux+ Wall Compact.
2. Home network (Wi-Fi)
The connection to the Wi-Fi home network can be established with both the app for the user and the app for the installer.

TIP

- If the Renson Flux+ Wall Compact is connected to a network via the user app, a connection between the installer app and the Renson Flux+ Wall Compact can still be established directly via the Wi-Fi dongle.
- If a Wi-Fi dongle is unplugged and then plugged in again:
 - In Access Point mode: the connection must be made again
 - In Client Mode: the connection to the network will be re-established automatically (even if the Wi-Fi dongle is plugged into the other USB port).
- If the Status LED module lights up white, the Renson Flux+ Wall Compact cannot connect to the network.

• Wi-Fi dongle activation

- Plug Wi-Fi dongle in USB poort
- Power up the unit and wait approximately 1 minute
- The Renson Flux+ Wall Compact automatically opens for 4 hours to connect with the Renson Installer App. Pressing the button ends the open period for establishing the connection.

After the 4 hours have elapsed, the Renson Flux+ Wall Compact can be reactivated for 4 hours by pressing and holding the user button (C) for more than 15 seconds.

• Reset Wi-Fi dongle


Long press (between 5 and 10 seconds) the button in the hole.

→ Disconnect the link with the home network (Wi-Fi) and/or installer app. Activation then allows you to reconnect to a (different) home Wi-Fi network or the installer app.

Resetting may be necessary in the following circumstances:

- To connect the Renson Flux+ Wall Compact to another network.
- The Renson Flux+ Wall Compact can no longer connect to the installer app or the home network.

8.5.2 • LAN connection



Via LAN connection you can plug an Ethernet cable into the network port as a wired alternative to the Wi-Fi dongle. This also allows you to connect to:

1. Renson Installer app

To do this, your mobile phone must be connected to your home network, no 'Flux' network will appear in your phone's Wi-Fi settings.


2. Home network (Wi-Fi)

Thanks to the network cable, the device is automatically connected to the home network.

 TIP

- If the Flux device is connected to the network via an Ethernet cable, the installer can still connect to the device directly via the Wi-Fi dongle.
- The connection is activated by plugging the Wi-Fi dongle into the USB port and then pressing and holding the user button (C) for more than 15 seconds.

8.6 • Connectivity Led strip



This LED indicates the device's connection status when using the Wi-Fi dongle. If the device is connected to the home network via an Ethernet cable, this LED will not light up.

OFF



The Flux ventilation unit is offline.

BLINKING BLUE



The unit is operating in access point (AP) mode, allowing the Flux ventilation unit to connect to your smartphone and change (Wi-Fi) settings. AP mode is activated for 4 hours by pressing the user push button (C) for a long time (>15 sec).

BLINKING BLUE-GREEN



The Flux ventilation unit has successfully connected to the home network and AP is still active.

GREEN



The Flux ventilation unit is permanently connected to the home network, either via the Wi-Fi dongle.

9 • Digital support from start to finish

9.1 • Installer web portal


The Renson Installer Portal offers the following benefits:

- Projects can be created in advance at the office, with all pulse and extraction valves and their corresponding values ready in the app. This will ensure there is no loss of time on site.
- Installation data can be tracked
- Management of all installations
- Digitisation of paperwork (preparatory administrative work)

Start up the web portal using the link <https://installer.renson.eu/>

The account created in the installation app or web portal grants access to both.

Situation sketch: how/where/when the app and web portal are used within the installation process.




Instructional videos from the web portal:
<https://installer.renson.eu/>



9.2 • Installation report

Starting up the Flux+ Wall Compact with the Renson Installer App has the great advantage that all installation parameters are kept up to date in the installer's web portal (Paragraph 8.4).

A digital installation report with the installation data can then be automatically created in the web portal and sent to the parties involved.



10 • Maintenance

10.1 • Periodicities

Regularly replacing the filters forms the foundation for proper maintenance of any D system. This ensures no unnecessary contamination will occur in the relatively sensitive heat exchanger. This maintains efficiency and energy consumption. In addition, there are other inspections and cleaning tasks that should ideally be carried out on components such as the valves, the condensate drain, fans, air ducts, and so on.

Part	Action	Frequency			
		M	3M	J	3J
DEVICE-SPECIFIC					
Filters	Visual inspection	●			
	Vacuum		●		
	Replace			●	
Condensate drain	Check			●	
Fans	Visual inspection			●	
	Clean				●
Heat exchanger	Visual inspection			●	
	Clean				●
NOT DEVICE-SPECIFIC					
Valves	Inspection		●		
	Clean			●	
Supply and extraction louvres	Inspection		●		
	Clean			●	
Ventilation ducts	Inspection			●	
	Clean (bacteriological)				●

The frequency for each part can be found via the link below:

<https://renson.net/gd-gb/blog/ventilation-system-maintenance-vital-but-often-forgotten>



10.2 • Cleaning and replacing filters


Do not use sprays, abrasives, detergents, solvents or chlorine-containing cleaning agents. They can cause damage to the filters.

You can dry clean the filters with a vacuum cleaner or you can replace them. In either case, you will need to remove the filters as shown below. The filter must be replaced in response to a filter message. As a result, the unit displays that the filter needs to be replaced (see Paragraph 8.6 for more information about the filter message). If the installation was connected to Renson room sensors, the filter notification will also be indicated on the display of the Renson room sensors.

NOTE


Ensure there is no voltage applied to the unit. To do this, remove the plug from the wall socket or switch off the circuit breaker.

1. Remove the filter covers.




Removing the filter covers.

2. Replace or clean the filters, according to the stated maintenance intervals (see Paragraph 10.1 Periodicities)



Removing the filter to clean or replace the filter.

3. Clean the filters using a vacuum cleaner. If you vacuum the filters regularly, the filter may show signs of wear. If so, replace the filter to continue to guarantee the correct functioning of the system.



4. Once you have ensured the filters are properly in place, replace the filter covers. The filters cannot be placed in the wrong direction.
5. Press the large button for 5 to 15 seconds (see Paragraph 8.4) to reset the filter message. This means you can enjoy the unit again without any worries.


10.3 • Cleaning the heat exchanger

You can clean or replace the heat exchanger. In either case, you must follow the procedure below to remove the heat exchanger. It is important to inform the end customer that cleaning the heat exchanger must not be carried out by the end customer.


NOTE

Ensure there is no voltage applied to the unit. To do this, remove the plug from the wall socket or switch off the machine.


1. Remove the two small filter covers at the front of the unit.




2. Loosen the two screws (PH2) that became visible after removing the filter covers.




3. Remove the front plate. All internal components now become visible.




4. Loosen and remove the remaining 7 screws (PH2).




5. Remove the condensate plate to access the heat exchanger.



6. Remove the heat exchanger.


TIP

You can hold the heat exchanger by the strap.




7. You can now clean the heat exchanger with clean warm water (max. 40°C) and washing up liquid. Under no circumstances should you use aggressive or dissolving cleaning agents!

- Rinse the heat exchanger sufficiently with clean warm water (max 40°C).

! WARNING

- Shake the water out of the heat exchanger and let it dry before placing it back in the unit.
- High-pressure cleaners may not be used on the heat exchanger.

- Make sure you place the heat exchanger back in the same position



8. Return all components in reverse order and close the unit.

10.4 • Cleaning the ventilation unit

If desired, the unit itself can be cleaned. To preserve the water-repellent properties of the housing, do not use soap or detergents to clean the inside of the unit. For the outside of the unit., soap and detergents may be used to a limited extent.

11 • Technical documentation

11.1 • Technical specifications

	Flux+ Wall Compact 275	Flux+ Wall Compact 350
Maximal flow rate	275 m³/h (at 200 Pa)	350 m³/h (at 200 Pa)
Thermal efficiency	Belgium - conform to Annex G of Annex V of the Energy Decree (conform to EN13141-7)	
	90% at 150 m³/h 88% at 200 m³/h 87% at 225 m³/h 86% at 275 m³/h	87% at 225 m³/h 86% at 275 m³/h 85% at 300 m³/h 84% at 350 m³/h
	ErP/EcoDesign (conform EN13141-7)	
	90,7% at 192,5 m³/h	90,2% at 245 m³/h
Maximal power consumption	2 × 55 W	2 × 80 W
Sound level (acc. to EcoDesign directive)	45,5 dB	48,5 dB
Energy class (acc. to Directive 2010/30/EU)	A+	A+
Power connection	220-240 V AC - 50/60 Hz Cable 2 m included (EU-plug)	
Dimensions	550 × 700 × 510 mm (H x W x D)	
Weight	21 kg	
Installation	Wall mount Left or right setup change only with software setting Floor mountingh by means of an accessory	
Connections	Ø160 mm internal diameter in the unit and external diameter of the supplied flanges Condensate connection D32 (1 ¼" external) Top and side connection for each connection point - Side connection on the ODA side only: no air flow loss - Side connection on the SUP side, whether or not combined with an ODA side connection: air flow loss possible up to 19%	
Bypass	Yes, complete (100%)	
Breeze functionality	Automatic passive cooling by temporarily running at nominal ventilation in case of a cooling need	
Frost protection	Default by unbalance Optional external accessory of 1,2kW allowing for hybrid frost protection mode	
Automatic flow control (constant flow)	Yes (± 5% accuracy)	
Fan	Quiet & energy-efficient EC motors with forward curved impeller	
Maximum fan working pressure	Up to 300 Pa - Recommended working pressure at design flow: ≤ 200 Pa - Guide value of a very good working pressure at design flow rate (cfr TV n° 258): 100 Pa to 150 Pa	
Display of system pressure	Via installer app & Renson installer web portal	
External input/output	- 1x Ethernet connection - 2x USB connections (USB dongle for Wi-Fi connection included*) - 3x digital inputs & outputs for ventilation level control and general feedback - Switch for error & filter status available	

* Only compatible with 2.4GHz

The full technical data sheet is available via this link:

https://dam.renson.net/asset/Offb1891-5643-42c8-bbad-403e5de56a8b/TF_Flux-_Wall_Compact_en.pdf



All photos shown are for illustration purposes only and merely serve as an example of a practical situation.
The actual product may vary due to modifications to the product.
Renson® reserves the right to make technical modifications to the products shown.
The most recent brochures are available for download at www.renson.eu



Renson® NV • Maalbeekstraat 10 • B-8790 Waregem
Tel. +32 56 30 30 00 • info@renson.be • www.renson.net