

Louvre Airflow Test


L.066P

BSRIA Final Report 60242/3

Carried out for
nv RENSON Sunprotection-Projects sa

By Andrew Freeth

13 July 2017



Louvre Airflow Test L.066P

Carried out for:

nv RENSON Sunprotection-Projects sa
Maalbeekstraat 6
B-8790 Waregem
Belgium

Contract: **BSRIA Final Report 60242/3**

Date: **13 July 2017**

Issued by: **BSRIA Limited**
Old Bracknell Lane West,
Bracknell,
Berkshire RG12 7AH UK

Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

E: bsria@bsria.co.uk W: www.bsria.co.uk

Compiled by: Name: Andrew Freeth Title: Senior Test Engineer BSRIA Test	Approved by: Name: Mark Roper Title: Principal Test Engineer BSRIA Test
--	--

DISCLAIMER

This report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This report has been prepared by BSRIA Limited, with reasonable skill, care and diligence in accordance with BSRIA's Quality Assurance and within the scope of our Terms and Conditions of Business.

This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at its own risk.

CONTENTS

1	INTRODUCTION.....	5
1.1	Test item information	5
2	TEST METHOD	7
2.1	Pressure drop	7
2.2	Test equipment used	7
3	RESULTS.....	8
3.1	Coefficient of Entry	8
3.2	Coefficient of Discharge	9

APPENDICES

APPENDIX: A	MANUFACTURER'S DRAWING.....	10
-------------	-----------------------------	----

FIGURES

Figure 1	Test item 60242A3 (front).....	6
Figure 2	Test item 60242A3 (rear).....	6

1 INTRODUCTION

This report concerns tests conducted on a louvre to determine the Pressure Drop versus Airflow Curve, with the associated Coefficient of Entry and Discharge using the test methods contained within EN 13030 : 2001. The work was commissioned by nv RENSON Sunprotection-Projects sa, and was carried out at BSRIA on 3 - 4 May 2017.

Items received for test

Test Item	BSRIA ID
L.066P	60242A3

1.1 TEST ITEM INFORMATION

Contract	60242
Date	3-5-17
Manufacturer	nv RENSON Sunprotection-Projects sa
Louvre Model	L.066P
Material	Aluminium
Painted	No
Core Area Height	983 mm
Core Area Width	983 mm
Blade Pack Depth	55 mm
Frame Depth	60 mm
No. of Blades	15
Blade Pitch	65 mm
Blade Angle	0° (to the air flow)
No. of Banks	1
Guard Type	None
Guard Spacing	N/A
Side Channels	No
Water Drip Tray	Yes
Blade Orientation	Horizontal

Note: Weather louvre core area - product of the minimum height H and minimum width W of the front opening in the weather louvre assembly with the louvre blades removed
Blade Pack Depth refers to the distance from front of first bank to rear of last bank.

Figure 1 Test item 60242A3 (front)




Figure 2 Test item 60242A3 (rear)



2 TEST METHOD

A schematic representation of the rig used during testing



2.1 PRESSURE DROP

For this test, the Aerodynamic Measuring Section (AMS) is separated from the main rig. The louvre is then mounted in the upstream opening of the AMS.

Pressure tappings in the plenum walls of the AMS allow measurement of the static pressure within the plenum during testing. The airflow volume is calculated from the differential pressure at the measuring cones. The plenum has a set of settling screens within to produce even flow through the cones and therefore gives an accurate reading of the total volume.

By adjusting the fan speed, the total airflow through the system varies and therefore changes the pressure on the louvre under test. A range of measurements are taken to give the characteristic curve for the test louvre.

2.2 TEST EQUIPMENT USED

Test equipment	BSRIA ID	Calibration Expiry Date
Airflow cones	364	7-1-18
Micromanometer	5	16-2-18
Micromanometer	682	2-2-18

3 RESULTS


3.1 COEFFICIENT OF ENTRY

MANUFACTURER nv RENSON Sunprotection-Projects sa
 MODEL L.066P

Date 03/05/2017
 Contract 60242

air temperature 16.5 °C louvre height 983 mm
 barometer 1014 mbar louvre width 983 mm
 air density 1.215 kg/m³ louvre area 0.966 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s	
8.2	1.96	1.897	3.551	0.534
9.1	2.05	1.979	3.741	0.529
10.9	2.24	2.166	4.094	0.529
12.6	2.41	2.331	4.401	0.530
14.8	2.61	2.521	4.770	0.529
18.6	2.91	2.813	5.348	0.526
21.9	3.17	3.061	5.803	0.528
29.4	3.67	3.544	6.723	0.527
36.8	4.09	3.952	7.522	0.525
42.5	4.42	4.271	8.084	0.528
mean C _e				0.529
Class				1



Graph equation $y = 2.2759x^{2.0226}$


3.2 COEFFICIENT OF DISCHARGE

MANUFACTURER nv RENSON Sunprotection-Projects sa
 MODEL L.066P

Date 03/05/2017
 Contract 60242

air temperature 16.5 °C louvre height 983 mm
 barometer 1014 mbar louvre width 983 mm
 air density 1.215 kg/m³ louvre area 0.966 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _d
	m/s	test m ³ /s	theoretical m ³ /s	
8.7	1.94	1.872	3.657	0.512
9.2	2.05	1.980	3.761	0.526
11.1	2.24	2.162	4.131	0.523
13.0	2.42	2.339	4.471	0.523
14.9	2.59	2.502	4.786	0.523
18.8	2.90	2.798	5.376	0.521
22.5	3.16	3.051	5.882	0.519
30.6	3.67	3.550	6.859	0.518
39.1	4.11	3.968	7.753	0.512
44.3	4.40	4.254	8.253	0.515
mean C _d				0.519
Class				1



Graph equation $y = 2.3367x^{2.0321}$

APPENDIX: A MANUFACTURER'S DRAWING

