

Weather Louvre Test

L.050IM2

Carried out for
nv Renson Ventilation sa

Report 61220/4

Compiled by Paul Ainscoe

5 December 2018



This page is intentionally left blank

Weather Louvre Test

L.050IM2

Carried out for: nv Renson Ventilation sa
Maalbeekstraat 10
8790 - Waregem
Belgium

Contract: Report 61220/4

Issued by: BSRIA Limited
Old Bracknell Lane West
Bracknell
Berkshire
RG12 7AH
UK

Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

Email: bsria@bsria.co.uk

Website: www.bsria.co.uk

QUALITY ASSURANCE

Issue	Date	Compiled by:	Approved by:	Signature
Draft	05-Dec-2018	Paul Ainscoe	Mark Roper	
		Test Engineer	Principal Test Engineer	

DISCLAIMER

This Document must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This Document has been prepared by BSRIA Limited, with reasonable skill, care and diligence in accordance with BSRIA's Quality Assurance and within the scope of our Terms and Conditions of Business.

This Document is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the Document at its own risk.

CONTENTS

1 INTRODUCTION.....5
 1.1 Test item information.....5
2 TEST METHOD7
 2.1 Water penetration.....7
 2.2 Pressure drop7
 2.3 Test equipment used7
3 RESULTS8
 3.1 Rainwater Penetration8
 3.2 Coefficient of Entry.....9
 3.3 Coefficient of Discharge10

FIGURES

Figure 1 Test item 61220A4 (front) 6
Figure 2 Test item 61220A4 (rear)..... 6

APPENDICES

APPENDIX A: MANUFACTURERS DRAWING 11

1 INTRODUCTION

This report concerns tests conducted on a louvre to determine the Rainwater Penetration and the Pressure Drop versus Airflow Curves, with the associated Coefficients of Discharge and Entry, using the test methods contained within EN 13030:2001. It should be noted that BS EN 13030:2001 simply provides a method for testing and rating louvre samples, there are no minimum permitted values or recommendations for louvre performance.

The work was commissioned by nv Renson Ventilation sa and was carried out at BSRIA North on 22 to 24 August 2018.

Items received for test

Test Item	BSRIA ID
L.050IM2	61220A4

1.1 TEST ITEM INFORMATION

Contract	61220
Date	20-8-18
Manufacturer	nv Renson Ventilation sa
Louvre Model	L.050IM2
Material	Aluminium
Painted	No
Core Area Height	975 mm
Core Area Width	995 mm
Blade Pack Depth	41 mm
Frame Depth	50 mm
No. of Blades	19
Blade Pitch	50 mm
Blade Angle	45° approx.
No. of Banks	1
Guard Type	None
Guard Spacing	N/A
Side Channels	No
Water Drip Tray	No
Blade Orientation	Horizontal

Note: Weather louvre core area - product of the minimum height H and minimum width W of the front opening in the weather louvre assembly with the louvre blades removed
Blade Pack Depth refers to the distance from front of first bank to rear of last bank.

Figure 1 Test item 61220A4 (front)




Figure 2 Test item 61220A4 (rear)



2 TEST METHOD

A schematic representation of the rig used during testing



The test comprises of two parts:

2.1 WATER PENETRATION

The weather louvre is subjected to fan driven wind at a speed of 13 m/s and water sprayed as rainfall at a rate of 75 l/h. In addition to the simulated wind and rain, air is drawn through the louvre at various set velocities (0, 0.5, 1.0, 1.5, 2.0, 2.5, 3.0 and 3.5 m/s).

Each test is preceded by a suitable 'pre-test' soak which is typically around 30 minutes. Each test is run until the results become stable, and in any case, for a minimum of 30 minutes.

The penetrated water is collected in the collection duct and is measured and recorded against time elapsed.

A range of measurements are taken to give the characteristic curve for the test louvre.

2.2 PRESSURE DROP

For this test, the Aerodynamic Measuring Section (AMS) is separated from the main rig. The louvre is then mounted in the upstream opening of the AMS.

Pressure tappings in the plenum walls of the AMS allow measurement of the static pressure within the plenum during testing. The airflow volume is calculated from the differential pressure at the measuring cones. The plenum has a set of settling screens within to produce even flow through the cones and therefore gives an accurate reading of the total volume.

By adjusting the fan speed, the total airflow through the system varies and therefore changes the pressure on the louvre under test. A range of measurements are taken to give the characteristic curve for the test louvre.

2.3 TEST EQUIPMENT USED

Test equipment	BSRIA ID	Calibration Expiry Date
Water supply measurement	352	19-4-19
Rain measuring system	353	20-4-19
Airflow cones	364	17-1-19
Micromanometer	1600	21-12-18
Micromanometer	1601	21-12-18
Scales (water)	1599	26-6-19
Flow meter	1688	29-5-19

3 RESULTS


3.1 RAINWATER PENETRATION

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM2

Date 22/08/2018
 Contract 61220

Simulated rainfall	75	mm/hr	louvre height	975	mm
Wind speed	13.0	m/s	louvre width	995	mm
			louvre area	0.970	m ²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	100.2	9.7	86.6%	C
0.49	0.50	100.2	13.9	80.8%	C
0.97	1.00	100.2	16.3	77.6%	D
1.45	1.50	100.2	19.2	73.6%	D
1.94	2.00	100.2	26.2	64.0%	D
2.43	2.50	100.2	37.5	48.4%	D
2.91	3.00	100.2	46.4	36.2%	D
3.40	3.50	100.2	56.8	21.9%	D




3.2 COEFFICIENT OF ENTRY

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM2

Date 24/08/2018
 Contract 61220

air temperature 17.3 °C louvre height 975 mm
 barometer 1006 mbar louvre width 995 mm
 air density 1.201 kg/m³ louvre area 0.970 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s		test m ³ /s	theoretical m ³ /s	
10.8	1.19		1.151	4.114	0.280
24.4	1.76		1.711	6.183	0.277
37.4	2.17		2.105	7.655	0.275
51.4	2.55		2.473	8.975	0.276
63.8	2.84		2.753	9.999	0.275
78.4	3.13		3.039	11.084	0.274
93.9	3.40		3.295	12.130	0.272
107.0	3.63		3.523	12.949	0.272
122.0	3.89		3.771	13.827	0.273
138.0	4.12		3.996	14.705	0.272
mean C _e					0.274
Class					3



A 'trendline' for the above graph would follow $y = 8.111x^{2.0453}$


3.3 COEFFICIENT OF DISCHARGE

MANUFACTURER nv Renson Ventilation sa
 MODEL L.050IM2

Date 24/08/2018
 Contract 61220

air temperature 17.1 °C louvre height 975 mm
 barometer 1006 mbar louvre width 995 mm
 air density 1.202 kg/m³ louvre area 0.970 m²

louvre pd Pascals	louvre face velocity	air flow rate		coefficient C _d
	m/s	test m ³ /s	theoretical m ³ /s	
10.8	1.14	1.101	4.112	0.268
25.3	1.74	1.689	6.294	0.268
39.1	2.18	2.111	7.825	0.270
53.8	2.55	2.472	9.179	0.269
69.6	2.84	2.758	10.440	0.264
83.7	3.15	3.054	11.449	0.267
97.5	3.40	3.298	12.356	0.267
109.0	3.62	3.508	13.065	0.269
125.0	3.89	3.774	13.991	0.270
141.0	4.12	3.994	14.859	0.269
mean C _d				0.268
Class				3



A 'trendline' for the above graph would follow $y = 8.8899x^2$

APPENDIX A: MANUFACTURERS DRAWING

