

Weather Louvre Test

445/86 - L.060AC - No Insect Mesh, No Water Gutter

Carried out for
Renson Ventilation NV

Report 101232/1

Compiled by Paul Ainscoe

3 March 2020



This page is intentionally left blank

Weather Louvre Test

445/86 - L.060AC - No Insect Mesh, No Water Gutter

Carried out for: Renson Ventilation NV
Industriezone 2 Vijverdam Maalbeekstraat 10
Waregem
8790
Belgium

Contract: Report 101232/1

Issued by: BSRIA Limited
Old Bracknell Lane West
Bracknell
Berkshire
RG12 7AH
UK


Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

Email: bsria@bsria.co.uk

Website: www.bsria.co.uk

QUALITY ASSURANCE

Issue	Date	Compiled by:	Approved by:	Signature
FINAL	03-Mar-2020	Paul Ainscoe	Mark Roper	
		Technician	Principal Test Engineer	

DISCLAIMER

This Document must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

This Document has been prepared by BSRIA Limited, with reasonable skill, care and diligence in accordance with BSRIA's Quality Assurance and within the scope of our Terms and Conditions of Business.

This Document is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the Document at its own risk.

CONTENTS

1	INTRODUCTION.....	5
1.1	Test Item Information	5
2	TEST METHOD	7
2.1	Water Penetration.....	7
2.2	Pressure Drop.....	7
2.3	Test equipment used.....	7
3	RESULTS	8
3.1	Rainwater Penetration	8
3.2	Coefficient of Entry.....	9
3.3	Coefficient of Discharge	10

FIGURES

Figure 1	Test item 101232A6 (front)	6
Figure 2	Test item 101232A6 (rear)	6

APPENDICES

APPENDIX A:	Manufacturer's Drawing	11
-------------	------------------------------	----

1 INTRODUCTION

This report concerns tests conducted on a louvre to determine the Rainwater Penetration and the Pressure Drop versus Airflow Curves, with the associated Coefficient of Entry, using the test methods contained within BS EN 13030:2001. It should be noted that BS EN 13030:2001 simply provides a method for testing and rating louvre samples, there are no minimum permitted values or recommendations for louvre performance.

The work was commissioned by Renson Ventilation NV and was carried out at BSRIA North from 27 January to 3 February 2020.

Items received for test

Test Item	BSRIA ID
445/86 – L.060AC – No Insect Mesh, No Water Gutter	101232A6

1.1 TEST ITEM INFORMATION

Contract	101232
Date	21/Jan/2020
Manufacturer	Renson Ventilation NV
Louvre Model	445/86 – L.060AC – No Insect Mesh, No Water Gutter
Material	Aluminium
Painted	No
Core Area Height	950 mm
Core Area Width	1000 mm
Blade Pack Depth	60 mm
Frame Depth	85 mm
No. of Blades	16
Blade Pitch	60 mm
Blade Angle	45° approx.
No. of Banks	1
Guard Type	None
Side Channels	No
Water Drip Tray	No
Blade Orientation	Horizontal

Note: Weather louvre core area - product of the minimum height H and minimum width W of the front opening in the weather louvre assembly with the louvre blades removed
Blade Pack Depth refers to the distance from front of first bank to rear of last bank.

Figure 1 Test item 101232A6 (front)




Figure 2 Test item 101232A6 (rear)



2 TEST METHOD

A schematic representation of the rig used during testing



The test comprises of two parts:

2.1 WATER PENETRATION

The weather louvre is subjected to fan driven wind at a speed of 13 m/s and water sprayed as rainfall at a rate of 75 l/h (+10% / -0%). In addition to the simulated wind and rain, air is drawn through the louvre at various set velocities (0, 0.5, 1.0, 1.5, 2.0, 2.5, 3.0 and 3.5 m/s).

Each test is preceded by a suitable 'pre-test' soak which is typically around 30 minutes. Each test is run until the results become stable, and in any case, for a minimum of 30 minutes.

The penetrated water is collected in the collection duct and is measured and recorded against time elapsed. A range of measurements are taken to give the characteristic curve for the test louvre.

2.2 PRESSURE DROP

For this test, the Aerodynamic Measuring Section (AMS) is separated from the main rig. The louvre is then mounted in the upstream opening of the AMS.

Pressure tappings in the plenum walls of the AMS allow measurement of the static pressure within the plenum during testing. The airflow volume is calculated from the differential pressure at the measuring cones. The plenum has a set of settling screens within to produce even flow through the cones and therefore gives an accurate reading of the total volume.

By adjusting the fan speed, the total airflow through the system varies and therefore changes the pressure on the louvre under test. A range of measurements are taken to give the characteristic curve for the test louvre.

2.3 TEST EQUIPMENT USED

Test equipment	BSRIA ID	Calibration Expiry Date
Rain measuring system	353	19-12-20
Airflow cones	364	24-01-21
Fan	484	19-12-20
Flow meter	1688	17-06-20
Scales (water)	1599	15-05-20
Micromanometer	1600	19-12-20
Micromanometer	1601	19-12-20
Temperature and Pressure Gauge	1605	31-07-20
Water supply measurement	1749	20-12-20

3 RESULTS

3.1 RAINWATER PENETRATION

Manufacturer Renson Ventilation NV


Date 27/01/2020

Model 445/86 - L.060AC - No Insect Mesh, No Water Gutter

Contract 101232

Simulated Rainfall	75 (+10% / -0%)	mm/hr	Core Area Height	950	mm
Wind Speed	13	m/s	Core Area Width	1000	mm
			Core Area Area	0.950	m ²

Ventilation Rate		Water Flow Rates		Effectiveness %	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	97.2	12.9	83.3	C
0.48	0.50	97.2	20.5	73.5	D
0.95	1.00	97.2	28.6	63.2	D
1.42	1.50	97.2	38.4	50.6	D
1.90	2.00	97.2	48.4	37.6	D
2.37	2.50	97.2	55.5	28.5	D
2.85	3.00	97.2	59.5	23.5	D
3.32	3.50	97.2	62.2	20.2	D



3.2 COEFFICIENT OF ENTRY

Manufacturer Renson Ventilation NV

Date 03/02/2020

Model 445/86 - L.060AC - No Insect Mesh, No Water

Contract 101232

Gutter

Air Temperature 16.1 °C


Core Area Height 950 mm

Barometer 1005.6 mbar

Core Area Width 1000 mm

Air Density 1.206 kg/m³Core Area Area 0.950 m²

Louvre p.d. Pa	Louvre Face Velocity	Air Flow Rate		Coefficient C _e
	m/s	Test m ³ /s	Theoretical m ³ /s	
10.4	1.25	1.185	13.175	0.302
21.1	1.79	1.704	12.232	0.305
32.3	2.24	2.126	11.540	0.305
42.8	2.57	2.439	10.692	0.306
54.9	2.92	2.775	9.854	0.307
64.9	3.19	3.027	9.064	0.306
76.4	3.45	3.273	8.003	0.305
89.0	3.71	3.525	6.952	0.306
100.0	3.93	3.730	5.619	0.303
116.0	4.19	3.981	3.945	0.300
Mean C _e				0.305
Class				2



A 'trendline' for the above graph would follow $y = 73314x^{1.9815}$

3.3 COEFFICIENT OF DISCHARGE

Manufacturer Renson Ventilation NV

Date 03/02/2020

Model 445/86 - L.060AC - No Insect Mesh, No Water

Contract 101232

Gutter

Air Temperature 15.9 °C


Core Area Height 950 mm

Barometer 1005.7 mbar

Core Area Width 1000 mm

Air Density 1.207 kg/m³Core Area Area 0.950 m²

Louvre p.d. Pa	Louvre Face Velocity	Air Flow Rate		Coefficient C _d
	m/s	Test m ³ /s	Theoretical m ³ /s	
10.8	1.30	1.233	12.589	0.318
22.0	1.90	1.802	11.811	0.319
32.2	2.30	2.184	11.180	0.319
42.3	2.67	2.540	10.426	0.318
51.6	2.95	2.802	9.721	0.317
63.2	3.24	3.082	8.783	0.319
72.7	3.49	3.320	7.953	0.319
83.6	3.75	3.564	6.939	0.315
93.3	3.97	3.767	5.735	0.314
106.0	4.21	3.999	4.018	0.307
Mean C _d				0.317
Class				2



A 'trendline' for the above graph would follow $y = 7.0684x^{1.9422}$

APPENDIX A: MANUFACTURER’S DRAWING

